

Fifth Biennial Transmission Assessment 2008-2017

Table of Appendices

Appendix A - Guiding Principles for Determination of System Adequacy and Reliability	Appendix A-1
Transmission	Appendix A-1
Appendix B – History of Commission Ordered Studies	Appendix B-1
Appendix C - RMR Conditions and Study Methodology.....	Appendix C-1
Appendix D - Questions Posed to Industry and Stakeholders – Workshop 1	Appendix D-1
Appendix E - 2008 BTA Workshop I and II List of Attendees.....	Appendix E-1
Appendix F – Listing of Terminology and Acronyms	Appendix F-1
Appendix G – WestConnect Annual Adequacy Study	Appendix G-1
Appendix H – WestConnect Biennial Long Range Study.....	Appendix H-1
Appendix I – References Of Information	Appendix I-1

APPENDIX A - GUIDING PRINCIPLES FOR DETERMINATION OF SYSTEM ADEQUACY AND RELIABILITY¹

This document serves the dual purpose of providing the guiding principles for ACC Staff determination of electric system adequacy and reliability in the two areas of transmission and generation.

Transmission

A.R.S §40-360.02E obligates the Arizona Corporation Commission (ACC) to biennially make a determination of the adequacy and reliability of existing and planned transmission facilities in the state of Arizona. Current state statutes and ACC rules do not establish the basis upon which such a determination is to be made. Therefore, ACC Staff will use the following guiding principles to make the required adequacy and reliability determination until otherwise directed by state statutes or ACC rules.

1. Transmission facilities will be evaluated using Western Systems Coordinating Council (WECC), or its successor's, Reliability Criteria for System Planning and Minimum Operating Reliability Criteria.
2. Transmission planning and operating practices traditionally utilized by Arizona electric utilities will apply when more restrictive than WECC criteria.
3. Compliance with A.C.C. R14-2-1609.B² will be established by analysis of power flow and transient stability simulation of single contingency outages (n-1) of generating units, EHV and local transmission lines of greater than 100 kV nominal system voltage, and associated transformers. Relying on remedial actions such as generator unit tripping or load shedding for single contingency outages will not be considered an acceptable means of complying with this rule.

Generation

¹ Guiding Principles for ACC Staff Determination of Electric System Adequacy and Reliability: Arizona's Best Engineering Practices, Jerry D. Smith, ACC, pre-filed comments for the Gila Bend Power Plant Hearing, Docket No. E-00000V-00-0106, November 9, 2000

² R14-2-1609.B refers to the obligation of Utility Distribution Companies to assure that adequate transmission import capability and distribution system capacity are available to meet the load requirements of all distribution customers within their service area.

Pursuant to A.R.S. §40-360.07, the ACC must balance, in the broad public interest, the need for adequate, economical, and reliable supply of electric power with the desire to minimize the effect on the environment and ecology of the state when considering the siting of a power plant or transmission line. The laws of physics dictate that generation and transmission facilities are inextricably linked when considering the reliability of service to consumers. Therefore, it is appropriate that both components must be considered when siting a power plant. ACC Staff will use the following guiding principles to make the required adequacy and reliability determination for siting generation until otherwise directed by state statutes or ACC rules.

The best utility practices historically exhibited in the evolution of Arizona's generation and transmission facilities should be continued in order to promote development of a robust energy market. Non-discriminatory access to transmission and fair and equitable business practices must also be maintained and the service reliability to which the state is accustomed must not be compromised. Therefore, Staff support of power plant Certificate of Environmental Compatibility applications will be conditioned as set forth below.

ACC Staff support of power plant Certificate of Environmental Compatibility applications will be contingent upon the applicant providing, either in the application or at the hearing, evidence of items 1-3 below:

1. Two or more transmission lines must emanate from each power plant switchyard and interconnect with the existing transmission system. This plant interconnection must satisfy the single contingency outage criteria (n-1) without reliance on remedial action such as generator unit tripping or load shedding.
2. A power plant applicant must provide technical study evidence that sufficient transmission capacity exists to accommodate the plant and that it will not compromise the reliable operation of the interconnected transmission system.
3. All plants located inside a transmission import limited zone "must offer" all Electric Service Providers and Affected Utilities serving load in the constrained load zone, or their designated Scheduling Coordinators, sufficient energy to meet load requirements in excess of the transmission import limit.

ACC Staff support of power plant Certificate of Environmental Compatibility applications will further be contingent upon the Certificate of Environmental Compatibility being conditioned as provided in items 4-6 below:

4. The Certificate of Environmental Compatibility is conditioned upon the plant applicant submitting to the ACC an interconnection agreement with the transmission provider with whom they are interconnecting.
5. The Certificate of Environmental Compatibility is conditioned upon the plant applicant becoming a member of WECC, or its successor, and filing a copy of its WECC Reliability Criteria Agreement or Reliability Management System ("RMS") Generator Agreement with the ACC.
6. The Certificate of Environmental Compatibility is conditioned upon the plant applicant becoming a member of the Southwest Reserve Sharing Group, or its successor, thereby making its units available for reserve sharing purposes.

Approved by:

(Original Signed by Deborah R. Scott)

Deborah R. Scott

Director

Utilities Division

This date: (2/8/00)RS/jds:ESAR.doc

APPENDIX B – HISTORY OF COMMISSION ORDERED STUDIES

Local Area Transmission Import Study Requirements

In the First BTA, Staff identified five load pockets in Arizona that should be monitored for transmission import constraints: Phoenix, Tucson, Yuma, Mohave County and Santa Cruz County. The 2002 BTA added a sixth area located in Southeastern Arizona (Cochise County). The Cochise County area was added to the Commission's areas of concern due to a major blackout of the area in 2001. The 2004 BTA added Pinal County as a local area that needed to be monitored as well. Inclusion of Pinal County was prompted by the necessity of transmission providers to implement a remedial action scheme ("RAS") or special protection scheme ("SPS") for single contingencies with operation of the new Desert Basin and Sundance power plants and additional gas turbines at Saguaro Power Plant.

Cochise County and Santa Cruz County are served by radial transmission lines that result in interruption of service to significant numbers of customers for the outage of any one of the radial transmission lines serving these two counties. A study of the Cochise County Area was documented in the second BTA. At that time no Commission action was deemed necessary because local transmission switching capability was sufficient to minimize the outage time for customers. The Fourth BTA granted Southwest Transmission Cooperative ("SWTC") a time extension until January 2008 to resolve N-1 contingency violations for loss of the Apache to Butterfield or the Butterfield to San Rafael 230 kV line in its 2015 planning study and to file expansion plans to resolve those issues as part of its 2008-2017 ten year plan.

Santa Cruz County, on the other hand, is served by a single transmission line. The customer service and system impacts and risks associated with the loss of a single 115 kV line serving Santa Cruz County are well chronicled over prior BTA assessments and siting of the Gateway 345 kV transmission project.³ A NEPA environmental impact study has been concluded but federal records of decision and a Presidential Permit for the new 345 kV transmission line are still pending with federal agencies. Therefore UNSE installed a 20 MW generator in Nogales in 2004 and plan to upgrade the existing 115 kV line to 138 kV as interim solutions to ensure the ability to restore service.

TEP was required to file comments by June 30, 2007 to resolve concerns inside neighboring New Mexico and Western Area Power Administration ("WAPA") facilities identified in its preliminary study results for 2016.⁴ In addition, technical studies are to be performed and results filed with the

³ ACC Decision #64356

⁴ ACC Decision #69389, March 14, 2007, page 6, section 2.b.iii

Commission for the Cochise County Area to mitigate extended customer outages that resulted from an N-1-1 outage in 2007. A subcommittee of the Southern Arizona Transmission Study (“SATS”) subregional planning group has undertaken this later task.

The simultaneous import limit (“SIL”) and maximum load serving limits (“MSLC”) of each of the Arizona load pockets is generally established in conjunction with RMR studies. The Commission approved SIL and MSLC definitions and methodology for performing RMR studies is documented in Appendix C. Arizona’s subregional planning forums have also been performing a tenth year snapshot study of the state’s transmission system. Those studies have traditionally considered N-0 and N-1 contingencies and provide additional information regarding the transmission capability of each local load pocket.

The Third BTA required that future studies also demonstrate compliance with the WECC and NERC single contingency criteria overlapped with the bulk power system facilities maintenance (“N-1-1”) for the first year of the BTA analysis. Staff agreed with the subregional planning groups to limit the N-1-1 analysis to the tenth year for the 4th BTA. The tenth year N-1-1 assessment now only considers designated 230 kV and above planned projects as not in service and then N-1 contingencies are performed. This analysis is more strenuous than the NERC N-1-1 criteria. However, it does determine the possible system impact of a planned project either not getting built as planned or being delayed beyond the tenth year of the plan.

Reliability Must-Run Study Requirements

Previous BTAs also identified several of the local load pockets in Arizona where the load cannot be served using a normal economic merit order generation dispatch due to transmission limitations. During some portions of the year, generation units within the load pocket must be operated out of merit order to serve a portion of the local load. Such a resource requirement is often referred to as Reliability-Must-Run (“RMR”) generation. The RMR power generated from local generation may be more expensive than the power from outside resources; and may be environmentally less desirable. During RMR conditions, transmission providers must dispatch RMR generation to relieve the congestion on transmission lines.

The Commission’s generic electric restructuring docket established that existing Arizona transmission constraints would limit APS’ and TEP’s ability to deliver competitively procured power to less than the required 50% of Standard Offer Service’s load.⁵ The Commission stayed this requirement in its Track B proceedings. However, each UDC is still obligated to assure that adequate transmission import capability is available to meet the load requirements of all distribution customers within its service area.⁶ Known

⁵ Direct Testimony of Jerry D. Smith and rebuttal testimony of Cary Deise, Docket No. E-00000A-02-0051

⁶ A.A.C. R14-2-1609.B

transmission constraints result in APS and TEP being dependent upon local RMR generation to serve their peak load during certain hours of the year.

In order to provide the Arizona load pockets access to potentially less costly power, the ACC Track A Decision No. 65154 ordered the Arizona utilities to work with Staff to develop a plan to resolve RMR concerns, and include the results of such a plan in the 2004 BTA. The same Decision ordered APS and TEP to file annual RMR study reports with the Commission in concert with their January 31 ten-year plan, for review prior to implementing any new RMR generation strategies, until the 2004 BTA is issued. The utilities readily responded and began providing RMR studies in 2003.

The Third BTA Decision No. 65476 approved a collaborative RMR study plan agreed to by all Arizona transmission providers.⁷ The 2003 RMR study forum included only the transmission providers. In contrast, since 2004 the RMR process has been open to all interested parties through Arizona's subregional study forums. The Fourth BTA required that "RMR studies continue to be performed and filed with ten year plans in even numbered years for inclusion in future BTA reports and that:

- Future RMR studies provide more transparent information on input data and economic dispatch assumptions, and
- Arizona utilities collaborate with the Staff to develop and effectively implement more stringent criteria as appropriate for RMR areas in the 2006 BTA."

Extreme Contingency Study Requirements

Staff's concerns regarding the adequacy and reliability of the Arizona electric system began in 2000 with the rapid development of new generation projects interconnecting with the Palo Verde Nuclear Generating Station. These projects all proposed to interconnect at the new Hassayampa 500 kV switchyard but were not increasing the capacity of the existing transmission lines already connected to the Palo Verde marketing hub. Large quantities of generation capacity and energy were at risk of being interrupted or curtailed for single contingency outages or credible outages of multiple lines. In addition the generation projects were being developed solely for merchant's commercial interest without obligations to assure existing generation reserves were sufficient to cover the outage risks the projects posed.

⁷ Appendix C

Therefore the Utilities Division of the Commission developed "Guiding Principles for Determination of System Adequacy and Reliability"⁸ for Staff's use in power plant and transmission line siting cases. The Commission endorsed this document via its Decision No. 65476 for the Second BTA. Then Condition No. 23 of the CEC was placed on APS and SRP in the Palo Verde to Rudd 500 kV siting case to formally require a study be performed to properly address the risks associated with interconnection developments at the Palo Verde Hub resulting in the 3rd BTA the adoption of the Palo Verde Hub interconnection criteria,

"Require all future interconnections proposed at the Palo Verde Hub, either new generation or new transmission lines, must perform a risk assessment of the Hub to ascertain to what degree the proposed project mitigates the pre-existing risks to extreme outage events. This assessment must precede a project's application for a CEC with the Commission. The recommendations of the Palo Verde Risk Assessment report should be followed if a proposed project would otherwise exacerbate the existing risk at the Hub." ⁹

Since the initiation of the Commission's first BTA process Arizona has experienced several fire seasons with exposure to loss of multiple lines in a common corridor on forested lands. These events heightened the Commission's awareness of the state's vulnerability to loss of transmission lines in common corridors. These events were then upstaged by the major 500/230 kV transformer and 230/69 kV fires that occurred at Westwing and Deer Valley in 2004 and the Westwing 500/345 kV transformer fire in 2006. Therefore the third BTA required that the fourth BTA address and document extreme contingency outages studied for Arizona's major generation hubs and major transmission stations including identification of associated risks and consequences if mitigating infrastructure improvements were not planned. This extreme contingency study requirement was reinforced further when the Commission ordered the same requirement for the fifth BTA.

Renewable Energy Transmission Assessment Requirement

In the Fourth BTA, the Commission ordered a Renewable Energy Assessment stating specifically, "in the next BTA, Commission regulated electric utilities, in consultation with the stakeholders, should prepare an assessment of ATC for renewable energy and prepare a plan, including a description of the

⁸ Appendix A

⁹ ACC Decision No. 67457, December 14, 2004, page 4, section 7.e

location, amount and transmission needs of renewable resources in Arizona, to bring available renewable resources to load.”¹⁰ This newest study requirement is focused on exploring transmission delivery obstacles for renewable resources that may choose to develop within the state. This study requirement is intended to assure that Arizona utilities can successfully comply with the renewable portfolio standards adopted by the Commission in 2006.

¹⁰ ACC Decision No. 69389, March 22, 2007, page 8


APPENDIX C - RMR CONDITIONS AND STUDY METHODOLOGY

In the 2002 BTA, Staff proposed that any UDC currently relying on local generation, or foreseeing a future time period when utilization of local generation may be required to assure reliable service for a local area, should perform and report the findings of an RMR study as a feature of their Ten-Year Plan filing with the Commission in January, 2003 and 2004. The 2002 BTA defined a Generic RMR Study Plan that required utilities to:

1. Define annual simultaneous import limits (SIL) for each transmission import limited area.
2. Provide a listing of all local generation and associated operational attributes.
3. Define RMR conditions for each year of the Ten-Year Plan.
4. Provide a local generation sensitivity analysis.
5. Identify and study alternative solutions.
6. Perform comparative analysis and present worth analysis of alternative solutions.

RMR conditions, required from RMR studies, are defined in the 2002 BTA and graphically presented in the following Figure 1.¹¹

Figure 1 – RMR Conditions



¹¹ 2002 BTA, Page 74-76

Essential RMR indicators that the Commission intends to receive from the RMR studies are:

- RMR hours - The number of hours during which the local load is above the SIL,
- RMR energy - The amount of energy served from RMR generation,
- RMR peak demand - The maximum RMR amount of capacity that the RMR generators would be required to produce,
- RMR costs - The costs of out-of-merit-order dispatch from RMR

The 2002 BTA established specific RMR procedures. The transmission system's simultaneous import limit (SIL) for each local constrained area is established for single contingencies (n-1) with no local generation in operation. An RMR condition exists during those times when the local load served by a UDC, or group of UDCs, exceeds that SIL. If no local generation exists for an RMR condition then the UDC(s) would have to utilize a load-shedding scheme for those contingencies that establish the SIL. This would imply a violation of WECC planning criteria since reliability practices are founded on the principle of continuity of service for single contingency outages.

When local generating units within the local load pocket are owned or under the operational control of the UDC(s), they are viewed as RMR units for the duration of the RMR condition. A local generating unit that is neither owned or under operational control of the UDC(s) may be considered a non-RMR unit. In some instances, a non-RMR unit may have a "must-offer" requirement to assure that system reliability is maintained. A local non-RMR unit that is operational during the hours an RMR condition exists will have the automatic effect of mitigating the constraint to the extent it serves local load or its capacity and energy is scheduled out of the local load pocket.

Local generation, irrespective of its composition of RMR and non-RMR units, may offer an acceptable planning solution to RMR conditions. The local RMR condition is essentially mitigated when local generation capacity and its associated voltage regulation ability is equal to or greater than that required to reliably serve the local RMR peak load. The question that needs to be answered is whether such dependence on local generation is prudent and in the consumers' best interest.

The maximum load serving capability (MLSC) of the local system is established by operating all local units at capacity, less local reserve requirements. The local MLSC equals to the SIL when there is no local generation. When local generation exists, the local MLSC is greater than the SIL but may fail to exceed the RMR peak load requirement. Such an RMR condition would require new transmission improvements or new local generation to assure reliable service to local consumers. When the MLSC is

greater than the local peak demand, then the RMR condition is mitigated and there is less risk that local load would be interrupted for local transmission or generation outages.

Utilization of reactive devices such as high voltage shunt capacitors, static or dynamic var compensators, or Flexible AC Transmission System (FACTS) control devices should be considered for voltage and var margin constrained SIL conditions. Similarly, maintaining a unity power factor at the sub-transmission bus of distribution substations and seasonal tap changes for transformers lacking automatic tap changer under load capability should be considered as a means of resolving voltage or var margin deficiencies. Advancing planned transmission lines or construction of previously unplanned lines should be among the alternatives studied for thermal and stability constrained SIL conditions.

A comparative analysis of all alternative solutions, including using local generation that mitigates the local RMR condition is to be documented. The following factors should be considered when documenting the merits of the various alternatives: impact on SIL, system reliability implications, system losses, operational flexibility, environmental effects, implementation requirements and lead-time, and opportunity for consumer benefits from competitive wholesale market. The following should also be identified in the comparative analysis of alternatives:

- The total expected cost, fixed and variable, for the local generation dispatch that results in the lowest local generation dispatch to mitigate annual RMR conditions.
- Total emission pollutants produced by the lowest local generation dispatch mitigating the annual RMR condition.

A present worth analysis of all alternative solutions is also to be performed. The cost analysis is to include an assessment of the total expected cost of operating local units versus remote units in combination with some transmission solution. Local and remote generation cost assumptions must be documented. The accuracy of RMR conditions depends upon technical studies, engineering assumptions and validity of data needed to determine:

1. Hourly load forecast for the future years.
2. SIL by ensuring that:
 - Aggregate local area load is the total substation load actually impacted by the transmission constraint;

- RMR generation within the local area is accurate; With RMR generation modeled out-of-service, the transmission system meets required normal (n-0) reliability criteria, showing no thermal and/or voltage limit violations;
 - With RMR generation modeled out-of-service, the transmission system meets required reliability criteria for all single contingency outages showing no thermal and/or voltage criteria violations; and
 - With RMR generation modeled out-of-service, the transmission system remains stable and shows no voltage instability.
3. RMR production costs by ensuring that:
- Analysis is done using industry recognized production-cost model.
 - Production-cost model database contains projected generation additions as accurate as possible, knowing in advance that future generation additions and unit commitments are dependent on many factors and are subject to change.
 - Hydro generation modeling reflects actual operating conditions as accurately as possible.
 - Thermal generation modeling reflects the current projection of variable operating and maintenance costs.
4. Comparison of the present worth of RMR production costs and present worth of transmission alternative costs.

APPENDIX D - QUESTIONS POSED TO INDUSTRY AND STAKEHOLDERS –
WORKSHOP 1

To help facilitate Workshop discussion the following questions were posed to all prospective workshop attendees and participants:

1. What transmission related topics or policy issues do you desire to have added to the proposed agenda?
2. What specific FERC/NERC/WECC policy, standards or mandatory reliability requirements would you recommend that the Commission consider in its evaluation of Arizona's transmission adequacy assessment?

Questions posed specifically to all parties that filed ten year plans, for addressing during their Workshop presentations included:

3. Describe all technical studies that were performed in support of your filed transmission plan?
4. List all reports that exist for the studies identified in item 3 and identify which reports were not included in your ten year plan filing.
5. Identify all transmission projects in your transmission plan for which power flow and stability analyses have not been performed or for which reports have not been filed. Describe how and when do you intend to respond with the required studies and reports?
6. Describe any stakeholder input and review that occurred regarding your transmission plan.
7. Please identify the subregional transmission planning forum(s) in which your transmission plan was addressed. Were your project(s) or planned facilities studied in that forum? Did your project(s) or plan undergo a peer review in that subregional forum and were they incorporated in the subregional plan?
8. Identify all projects in your filed transmission plans that were not addressed in a subregional transmission planning forum as described in item 7.

APPENDIX E - 2008 BTA WORKSHOP I AND II LIST OF ATTENDEES¹²

BTA Workshops I & II Attendees							
Last	First	Title	Representing	Phone	E-mail Address	Workshops Attended	
						Workshop 1	Workshop 2
Aguayo	Stacy	Reg. Relations Manager	APS	602-250-2681	stacy.aguayo@aps.com	X	
Aluther	Jeri	Attorney	Robert Lynch and Associates	602-254-5908	jeri@rslynchaty.com	X	X
Amirali	Ali	V.P. Transmission & Market	LS Power Development LLC	408-204-7630	aamirali@lspower.com	X	
Anderson	Erinn		APS		Erinn.anderson@aps.com		X
Atkins	Steve		NAU	928-607-6635	steve.atkins@nau.edu		X
Bagley	Ken	Manager	Genesee Consulting	623-748-8989	kabagley@cox.net	P	X
Bahl	Prem	Staff	ACC	602-542-7269	pbahl@cc.state.az.us	X	P
Bailey	Cindy	Project Assistant	Southwestern Power Group	602-808-2004	cbailey@southwesternpower.com	X	
Bailey	Michael	Engineer	Dynegy	713-767-4524	michael.bailey@dynegy.com	X	
Barajas	David	Supt & Gen.	Imperial Irrigation District	760-982-3450	dbarajas@iid.com	X	

¹² BTA Workshop I was held on May 22-23, 2008 and BTA Workshop II was held on September 18, 2008 at the Arizona Industrial Commission Auditorium

Decision No. 70635

Bates	Gary	Engineer	WAPA	602-605-2694	Bates@wapa.gov	X	
Beck	Ed	Superintendent Planning	TEP/UNSE	520-745-3276	ebeck@tep.com	P	
Belval	Ron	Planning Engineer	TEP	520-745-3420	rbelval@tep.com		X
Bloch	Steve		Bloch Communications	602-424-1730	steve@blochcommunications.com	X	
Brandt	Jana	Reg. Analyst	SRP	602-236-5028	jkbrandt@srpnet.com	X	X
Bryan	David	Engineer	SSVEC	520-720-6421	dbryan@ssvec.com	X	X
Bullock	Chris	Corp. Dev.	Atwell-Hicks	480-704-2644	-	X	
Byron	Don		Western	602-605-2685	Byron@wapa.gov	X	
Cabbell	Dana	Manager	SCE	626-302-0376	dana.cabbell@sce.com	P	X
Calkins	Ian	Public Affairs	Copperstate Consulting Group	602-229-1010	ian@copperstate.net	X	
Carr	Thomas A.		Sempra Energy	619-696-4246	tcarr@sempra.com	X	
Charters	Jim	Retired	N/A	623-572-7972	J_charters@msn.com	X	
Cobb	Steven		SRP			P	
Cole	Perry	Managing Director	Energy Capital	858-703-4445	pcole@ecpartners.com	X	
Cole	Brian	Manager Research Planning	APS	602-250-4332	brian.cole@aps.com	X	X
Couture	Dave	Director	TEP	520-884-3752	dcouture@tep.com		X
Deise	Cary		APS	602-250-1232	cary.dersi@aps.com	X	X
Delaney	Dennis	Partner	K.R. Saline & Associates, PLC	480-610-8741	dld@krsaline.com	P	
Drake	Peter	Principal Planner	Arizona Land Use Planners	602-955-7260	peter.drake@cox.net	X	
Etherton	Mark		PDS	602-809-0707	mark@pdsplc.com	X	

Decision No. 70635

Evans	Bruce	Engineer	SWTC	570-586-5336	bevans@swtransco.coop		X
Fecke-Stoudt	Christopher	Engineer	K.R. Saline & Associates, PLC	480-610-8741	cmf@krsaline.com	X	X
Filippi	Jim		NextLight Renewable Power	415-946-8937	jfilippi@nextlightrp.com	X	
Fisher	Jim	Regional Director Development	Transwestern Pipeline	281-414-5332	jfisher@Energy.com	X	
Foreman	John	Chairman	AZ Siting Committee		John.Foreman@azag.gov	X	X
French	David		Town of Buckeye, Lyle Anderson Co.	480-735-8708	frenchaz@gmail.com	X	
Gardner	Jeff	V.P. Regulations	APS	602-250-2952	jeff.gardner@aps.com	X	
Gazda	Mike		APA	602-542-4263	mike@powerauthority.org	X	
Hains	Charles	Staff	ACC	602-542-3402	chains@azcc.gov	X	
Russell	Chuck	Engineer	SRP	602-236-0975	Chuck.Russell@srpnet.com	X	
Hernandez	John		SRP	602-236-0968	Johnny.Hernandez@srpnet.com	X	
Herrera	Joseph	Director of ERO	ED3	520-424-9311	joseph@ed-3.org	X	
Hoisington	Ben		DPA	928-871-2260	dpabenb@citbank.net	P	
John	Eric	Developer	SkyFuel	505-999-5823	eric.john@skyfuel.com		X
Johnson	Jeff		APS	602-250-2661	Jeffrey.Johnson@aps.com	X	
Keel	Brian	Manager, TSP	SRP	602-236-0970	briankeel@srpnet.com	X	
Klemstine	Barbara	Director Regulatory	APS	602-250-4563	Barbara.Klemstine@aps.com	X	
Kondziolka	Robert		SRP	602-236-0971	robert.kondziolka@srpnet.com	P	X
Krzykos	Peter		APS	602-850-1649	Peter.krzykos.com	P	X
Kubiak	Sarah		Fennemore Craig	602-916-5478	skubiak@felaw.com		X
Leslie	Padilla	Director	SempraGen	619-696-4425	lpadilla@semprageneration.com	X	

Decision No. 70635

Lockwood	Barbara	Manager	APS	602-250-3361	barbara.lockwood@aps.com	X	
Lucas	John	Manager	APS	602-250-1144	John.Lucas@aps.com	P	X
Maracas	Kate	VP Operations	Abengoa Solar	480-705-9439	Kate.maracas@solar.abengoa.com		X
Maurer	Kurt		ADEQ	602-771-4500	kem@azdeg.gov	X	
McElhany	Michael	Compliance Manager	WAPA – DSW	602-605-2662	Mcelhany@wapa.gov	X	
McEwen	Glen	Corp. Development	Atwell-Hicks	480-704-2644	-	X	
Mehta	Parthavi	Computer Analyst	SRP	602-236-3991	parthavi.mehta@srpnet.com	X	
Ormond	Amanda		Ormond Group	480-491-3305	asormond@msn.com	X	X
Percival	Milt	Manager	WSES	480-994-8695	mperc7439@aol.com	X	X
Patterson	Greg	AZCPAORG		602-369-4368	greg@azcpa.org	X	X
Piatt	Elise	Public Affairs Advisor	Tnadvocates UC	602-881-8671	elise@tnadvocates.com	X	
Pickles	Jim	Associate Director	AUSRA	480-522-4025	Jim.Pickles@ausra.com	X	
Quinn	Phil	Attorney	Navopache	602-393-1760	iquinn@cgsuslaw.com	X	X
Rein	Jim	Manager TX PL	SWTC	520-586-5116	jrein@swttransco.coop	P	X
Reinhold	Charles		WestConnect	208-253-6916	reinhold@globalcrossing.net	P	
Romero	Gary	Lead Engineer	KRSA	480-610-8741	gtr@krsaline.com		X
Russell	Chuck	Engineer	SRP	602-236-0975	Chuck.Russell@srpnet.com	P	
Sandler	Vicki	Executive Director	AZISA	602-625-7879	vickisandler@gmail.com	X	
Scott	Deb		APS	602-250-5508	deb.scott@pinnaclewest.com	X	X
Sheehan	Mike		TEP	520-884-3656	mshsheehan@tep.com	X	
Siggard	Debbie		Fennemore Craig	602-916-5478	dsiggard@felaw.com	X	
Silva	Jose	Engineer	SRP	602-236-0962	Jose.Silva@srpnet.com	P	

Decision No. 70635

Smith	Bob	Engineer	APS			P	
Smith	Del	ACC Staff	Utility Division	602-542-7277	dsmith@azcc.gov		X
Smith	Paul	Manager	APS	602-250-2350	paul.smith@aps.com	P	
Smith	Jerry	T&D Manager	K.R. Saline & Associates, PLC	480-610-8741	jds@krsaline.com	X	P
Smithers	Phil	Leader	APS	602-250-4250	Phil.smithers@aps.com		X
Spitzkoff	Jason	Engineer	APS	602-250-1651	jason.spitzkoff@aps.com	X	
Stahlhut	Jonathan	Engineer	APS	602-250-1116	jonathan.stahlhut@aps.com	P	
Szot	Lisa		N.M. RETA	505-992-9627	-	X	
Theaker	Brian	Director Reg. Affairs	Dynegy	530-295-3305	brian.theaker@dynegy.com	X	X
Vaninetti	Jerry		High Plains Express			P	
Williamson	Ray	Engineer	ACC		-	X	X
Woodall	Laurie	Project Manager	K.R. Saline and Associates, PLC	480-610-8741	law@krsaline.com	P	P
Wray	Thomas A.	Project Manager	SunZia	602-808-2004	twray@southwesternpower.com	P	X

APPENDIX F – LISTING OF TERMINOLOGY¹³ AND ACRONYMS¹⁴

Terminology

Arizona Power Plant and Transmission Line Siting Committee: The committee that reviews proposals to construct power plants and transmission lines in Arizona. In 1971, the Arizona Legislature required that the Commission establish a power plant and line siting committee. The Committee provides a single, independent forum to evaluate applications to build power plants (of 100 megawatts or more) or transmission projects (of 115,000 volts or more) in the state. The Committee holds meetings and hearings that are open to the public. [Click here to learn more about the Siting Committee.](#)

Bundled service: Electric service provided as a package to the consumer including all generation, transmission, distribution, ancillary and other services necessary to deliver and measure useful electric energy and power to consumers.

Certificate of Convenience & Necessity (CC & N): A document granting operating authority to utilities.

Competitive services: All aspects of retail electric service except those services specifically defined as "Noncompetitive Services" pursuant to Corporation Commission Rules [R14-2-1601\(29\)](#) or noncompetitive services as defined by the Federal Energy Regulatory Commission.

Continuity of Service¹⁵: Each utility shall make reasonable efforts to supply a satisfactory and continuous level of service. With respect to the Fifth BTA, use of this term describes the desire for "continuity of service" following the loss of a transmission line.

Demand: The rate at which power is delivered during any specified period of time. Demand may be expressed in kilowatts, kilovolt-amperes or other suitable units.

Distribution lines: The utility lines operated at distribution voltage, which are constructed along public roadways or other bona fide rights-of-way, including easements on customer's property.

Distribution service: The delivery of electricity to a retail consumer through wires, transformers, and other devices that are not classified as transmission services subject to the jurisdiction of the Federal Energy Regulatory Commission. Distribution service excludes metering services, meter reading services and billing and collection services, as those terms are used herein.

Electric Service Provider (ESP): A company supplying, marketing or brokering at retail any competitive services pursuant to a Certificate of Convenience and Necessity approved by the Corporation Commission.

Environmental Portfolio Standard (EPS): A ruling by the Commission that requires any company serving electricity to an end-user to generate a portion of that electricity through renewable technologies such as wind, solar, biomass generators or landfill gas recovery.

Federal Energy Regulatory Commission (FERC): An independent regulatory agency within the US Department of Energy that, among other things, regulates interstate oil, natural gas and power transmission sales.

¹³ <http://www.cc.state.az.us/divisions/utilities/electric/terms.asp>

¹⁴ Listing of Acronyms obtained from Fourth Biennial Transmission Assessment, Page 1

¹⁵ Except from Arizona Administrative Code, R14-2-208(C)

http://www.azsos.gov/public_services/Title_14/14-02.pdf

Generation: The production of the actual megawatts of electricity or purchase of electricity through the wholesale market.

Green pricing: A program offered by an Electric Service Provider where customers elect to pay a rate premium for renewable generated electricity.

Pancaking: A term used to describe the layering of multiple tariff rates in point to point transactions.

PV Hub: Palo Verde power plant and switchyard, the Hassayampa switchyard, and the there 500 kV tie lines connecting the two switchyards.

Interruptible electric service: Electric service that is subject to interruption as specified in the utility's tariff.

Kilowatt (kW): A unit of power equal to 1,000 watts.

Kilowatt-hour (kWh): The electric energy equivalent to the amount of electric energy delivered in 1 hour when delivery is at a constant rate of 1 kilowatt.

Megawatt (MW): A unit of power equal to 1,000,000 watts.

Meter service: All functions related to measuring electricity consumption, including installation and repair of meters, but not including meter reading.

Point of Delivery: The point where facilities owned, leased or under license by a customer connects to the utility's facilities.

Power: The quantity of electricity being generated, transferred or used at any instant in time, usually expressed in kilowatts.

Service area: The territory in which the utility has been granted a Certificate of Convenience and Necessity and is authorized by the Commission to provide electric service.

Tariffs: The documents filed with the Corporation Commission which list the services and products offered by the utility and which set forth the terms and conditions and a schedule of the rates and charges for those services and products.

Transmission service: Refers to the transmission of electricity at high voltage to retail electric customers or to electric distribution facilities as defined by the Federal Energy Regulatory Commission (FERC) or Arizona Corporation Commission.

Utility: The public service corporation providing electric service to the public in compliance with state law, except in those instances set forth in Corporation Commission Rules, [R14-2-1612 \(A\) and \(B\)](#).

Utility Distribution Company (UDC): The electric utility entity regulated by the Commission that operates, constructs, and maintains the distribution system for the delivery of power to the end user point of delivery on the distribution system.

Acronyms

AC	Alternating Current	MORC	Minimum Operating Reliability Criteria
ACC	Arizona Corporation Commission	MOU	Memorandum of Understanding
ANPP	Arizona Nuclear Power Project	MVA	Megavolt-Ampere
APS	Arizona Public Service	MVAR	Megavolt-Ampere Reactive
ATC	Available Transfer Capability	MW	Megawatt
AZ	Arizona	n-0	No Contingency
AZNM	AZ-NM EHV Subcommittee	n-1	Single Contingency
BTA	Biennial Transmission Assessment	n-1-1	Overlapping Contingency
BTU	British Thermal Unit	n-2	Double Contingency
CA	California	NERC	North American Electric Reliability Corporation
CAO	Control Area Operator	NG	Natural Gas
CATS	Central Arizona Transmission System	NM	New Mexico
CAWCD	Central AZ Water Conservation District	NOI	Notice of Inquiry
CC	Combined Cycle	NOPR	Notice of Proposed Rulemaking
CDEAC	Clean and Diversified Energy Advisory Committee	NTP	Navajo Transmission Project
CEC	Certificate of Environmental Compatibility	OASIS	Open Access Same Time Information System
CRT	Colorado River Transmission Subcommittee	OATT	Open Access Transmission Tariff
DOE	Department of Energy	PJM	Pennsylvania-New Jersey-Maryland (ISO)
DPA	Dine Power Authority	PNM	Public Service of New Mexico
DSW	Desert Southwest Region	PURPA	Public Utilities Regulatory Policy Act
ED	Electric District	PV	Palo Verde
EFOR	Equivalent Forced Outage Rate	RMR	Reliability Must Run
EHV	Extra High Voltage	RMS	Reliability Management System
EOR	East of (Colorado) River	RTO	Regional Transmission Organization
EPACT	Energy Policy Act	SCE	Southern California Edison
EPS	Environmental Portfolio Standards	SCED	Security Constrained Economic Dispatch
ERO	Electric Reliability Organization	SDG&E	San Diego Gas and Electric
FACTS	Flexible AC Transmission System	SEV	South East Valley
FERC	Federal Energy Regulatory Commission	SIL	Simultaneous Import Limit
FOR	Forced outage rate	SRP	Salt River Project
FPA	Federal Power Act	SSG-WI	Seams Steering Group – Western Interconnection
GT	Gas Turbine	ST	Steam Turbine
HV	High Voltage	STEP	Southwest Transmission Expansion Planning Group
HVDC	High Voltage Direct Current	SWAT	Southwest Area Transmission Study Group
HY	Hydro	SWPG	Southwest Power Group
I/S	In-Service	SWTC	Southwest Transmission Cooperative
IID	Imperial Irrigation District	TEP	Tucson Electric Power
IPP	Independent Power Producer	TEPPC	Transmission Expansion Planning Policy Committee
ISO	Independent System Operator	TNMP	Texas-New Mexico Power Company
KRSA	K.R. Saline and Associates, PLC	TTC	Total Transfer Capability
kV	Kilovolt	UDC	Utility Distribution Company
kWh	Kilowatt-Hour	UNS	UniSource Energy Corp.
LSE	Load Serving Entity	WAPA	Western Area Power Administration (“Western”)
MISO	Midwest Independent System Operator	WECC	Western Electricity Coordinating Council
MLSC	Maximum Load Serving Capability	WGA	Western Governors’ Association

APPENDIX G – WESTCONNECT ANNUAL ADEQUACY STUDY

Purpose

This document describes a WestConnect subregional transmission study that will be performed annually for WestConnect by K.R. Saline and Associates, PLC (KRSA). The study results and associated report will be incorporated in the subsequent WestConnect Transmission Report.

Study Scope

WestConnect will annually perform a study to test the adequacy of its most recently published WestConnect Transmission Plan (“Plan”) excluding conceptual projects. The adequacy of the Plan will be determined by documenting system performance relative to WECC / NERC planning requirements. Traditional N-0, N-1 and N-2 contingency outages will be performed for the 5th and 10th year of the current planning period. Any deficiencies in the Plan will be noted with sufficient lead time for WestConnect subregional transmission planning participants to investigate solutions for incorporation into the subsequent WestConnect Transmission Plan.

In addition, potential corridor outages involving planned facilities will be modeled and the resulting system performance documented. These corridor outages will only be performed in the 10th year of the current planning period. The purpose is to ascertain what degree of system reliability risk is associated with placing proposed projects in common corridors with other facilities. Identification of such risks in advance of siting of new facilities is needed with sufficient lead time to explore alternative routes. It is not believed that studying such corridor outages in the 5th year of the study period would offer sufficient lead time to pursue alternate routes.

Required Base Cases

This study will utilize a 5th and 10th year base case developed and coordinated for use in WestConnect’s current subregional transmission planning cycle. The base case will incorporate the “sponsored and committed” transmission projects contained in the previously published WestConnect Transmission Plan. The base cases will not include the “conceptual” transmission projects contained in the WestConnect Transmission Plan because they either have no sponsorship or there is no firm commitment to build the projects by a specific date.

APPENDIX H – WESTCONNECT BIENNIAL LONG RANGE STUDY

Purpose

This document describes a long range subregional transmission study that will be performed biennially for WestConnect. The study results and associated report will be summarized in even numbered year WestConnect Transmission Reports.

Study Scope

WestConnect will biennially perform a technical study to explore conceptual long range transmission needs within the WestConnect planning area. The goal of the study is to develop and refine conceptual long range transmission options within the WestConnect planning area for the 10th year study time period and beyond. This study will focus solely on the WestConnect planning area's system performance for load forecasts and generation scenarios representative of this study period. Therefore, the study will be limited to power flow studies that investigate the system's performance for single contingency outages (N-1).

The scope of the WestConnect long range study will vary over time in order to address contemporary issues facing the industry. The conceptual projects studied in response to those contemporary issues will serve as an incubator for alternative transmission projects that may eventually become sponsored and added to a future WestConnect Transmission Plan. More importantly, the long range study process will broaden and extend the vision of future transmission line corridor needs in the WestConnect planning area.

The initial WestConnect long range study will serve a two fold purpose. The first relates to the transmission planning interface between the Transmission Expansion Planning Policy Committee's (TEPPC) economic studies of the Western Interconnection and subregional transmission planning groups. This functional study requirement will be a routine feature of the WestConnect long range study scope. The second initial long range study effort is exemplary of a contemporary industry issue: system wide integration of renewable energy projects.

1. The WestConnect long range study will provide traditional reliability oriented studies that investigate transmission solutions to long range congestion concerns raised by the annual TEPPC economic transmission expansion study report. This reliability based study effort will essentially complement and supplement the TEPPC transmission congestion study effort. As a result the study will need to explore a variety of generation expansion scenarios consistent with the prior TEPPC study. Results of this reliability based long range study will enable WestConnect to offer definitive conceptual transmission solution proposals for the subsequent TEPPC study cycle.
2. The initial long range study will explore conceptual transmission improvements needed to accommodate fully developed renewable resources located within the WestConnect planning area. This study effort will incorporate the findings of the NREL wind and solar integration study, the Colorado Energy Zones study, the New Mexico renewable energy collector study and the new SWAT AZ/NM renewable energy task force study effort.

Required Base Cases

This study will utilize a 10th year base case developed and coordinated for use in WestConnect's current subregional transmission planning cycle. The base case will incorporate the "sponsored and committed" transmission projects contained in the previously published WestConnect Transmission Plan. Additional base cases will be developed from the 10th year base case to model alternative renewable energy development scenarios and load forecast within the WestConnect planning area beyond the 10th year. These additional base cases will also model the "conceptual" transmission projects contained in the WestConnect Transmission Plan in a status "off" mode. The "conceptual" transmission projects will serve as a starter pool of potential transmission projects that could be called upon to ensure reliable service at higher load levels. Other conceptual transmission projects may be added to the pool of candidate projects as dictated by load and resource placement within the WestConnect study area.

APPENDIX I – REFERENCES OF INFORMATION

Transmission Planning Studies and related documents, used to develop this Fifth BTA report, were assembled from the following reports, presentations, and dockets:

Utilities' 2008 Ten-Year Transmission Plans

Arizona Public Service Company (APS)
Salt River Project (SRP)
Southwest Transmission Cooperative (SWTC)
Southwestern Power Group II (SWPG)
 SunZia
 Bowie
Southern California Edison (SCE)
Gila Bend Power Partners (GBPP)
Dynergy Arlington Valley, LLC
Wellton-Mohawk Irrigation and Drainage District (WMIDD)
Public Service Company of New Mexico (PNM)
Santa Cruz Water and Power District Association (SCWPD)
Tucson Electric Power Company (TEP)
El Paso Electric Company (EPE)
UniSource Electric (UNSE)
Western Area Power Administration (WAPA) - Unfiled

First Draft Comments and Workshop II Comment Summary Presentation

All comment in their entirety or the summary presentation can be found on ACC Commission Docket (<http://edocket.azcc.gov/>)

First, Second, Third and Fourth BTA Reports and 2008 Summer Preparedness Presentations

These reports and presentations can be found on the Arizona Corporation Commission website (www.cc.state.az.us/utility/electric/index.htm)

Arizona Corporation Commission's Docket Control

Items related to previous and present filings (<http://edocket.azcc.gov/>)

Reliability Must-Run Documents

ACC 2008 BTA Workshop I RMR Presentations and Reports

N-1-1 and Extreme Contingency Study Documents

ACC 2008 BTA Workshop I N-1-1 and Extreme Contingency Presentations

Transmission Projects Reports

Navajo Transmission Project (NTP)
Palo Verde-Devers 2 (PVD-2) – Southern California Edison
Harcuvar Project
Wellton-Mohawk Project
Three Terminal Plan (TTP) – Santa Cruz Water and Power District
Bowie Power Station
SunZia Southwest Transmission Project – Southwestern Power Group
High Plains Express Initiative
TransWest Express Initiative

Regional Committees and Working Groups Materials

Biennial Transmission Assessment for 2008-2017
Docket — **E-00000D-07-0376**

References
December 3, 2008

WestConnect Documents (www.westconnect.com)

Southwest Area Transmission (SWAT)

Arizona Renewable Task Force

Central Arizona Transmission Study - High Voltage (CATS-HV)

Central Arizona Transmission Study - Extra High Voltage (CATS-EHV)

Colorado River Transmission (CRT)

Southeastern Arizona Transmission Study (SATS)

Short Circuit Working Group (SCWG)

Federal Energy Regulatory Commission (FERC)

FERC Reliability Standards (www.ferc.gov)

North America Electric Reliability Council (NERC)

NERC Reliability Standards (www.nerc.com)

Western Electricity Coordinating Council (WECC) Standards and studies

The standards can be found on the WECC website (www.wecc.biz) under "Click here for library".

National Renewable Energy Laboratory

Support documents and reports (www.nrel.gov)

Western Governors Association (WGA)

Support documents and Report documents (www.westgov.org)

California Energy Commission Website

Information relating to RETI and California renewable activities (www.energy.ca.gov)

Nevada Renewable Energy Transmission Access Advisory Committee Website

Information relating to RETAAC and Nevada renewable activities (<http://gov.state.nv.us/Energy/>)

Colorado Clean Energy Development Authority Website

Information relating to CEDA and Colorado renewable activities

(<http://www.colorado.gov/energy/utilities/clean-energy-development-authority.asp>)

Large Generator Interconnection Queues (http://www.oatiosis.com/cwo_default.htm)

Arizona Public Service Company (APS)

Salt River Project (SRP)

Tucson Electric Power (TEP)

Western Area Power Administration (WAPA)