

## APS Major Transmission Facilities

### **Moenkopi 500kV Switchyard**

Ownership:

APS	14%
SRP	21.7%
TEP	7.5%
NEV	11.3%
LADWP	21.2%
WAPA	24.3%

Four Corners and Eldorado Reactors:

APS	24.7%
SRP	38.3%
TEP	13.3%
WAPA	23.7%

Westwing Reactors:

APS	100%
-----	------

In Service 1969

No Transformers

4 – 500kV Reactor Banks (Single and Three Phase)

Adequate spacing between reactor banks

### **Navajo 500kV Switchyard**

Ownership:

APS	14%
SRP	21.7%
TEP	7.5%
NEV	11.3%
LADWP	21.2%
WAPA	24.3%

Westwing Reactors:

APS	24.7%
SRP	38.3%
TEP	13.3%
WAPA	23.7%

Crystal Reactors:

NEV	26.1%
LADWP	48.9%
WAPA	25%

In Service 1975

No Transformers

2 – 500kV Reactor Banks (Single Phase)

Adequate spacing between reactor banks

## North Gila Substation

Switchyard:  
    APS           66.7%  
    SD&G        28.5%  
    IID           4.8%

Line Reactors:  
    APS           11%  
    SD&G        76.22%  
    IID           12.78%

Substation:  
    APS           100%

In Service 1983

1 – 500kV 500/69kV Transformer Bank (Single Phase)

    Fire walls to be added with transformer addition in 2005

1 – 500kV Reactor Bank (Single Phase)

## Saguaro Substation

Switchyard and Substation:  
    APS           100%

Tortolita:  
    TEP           100%

In Service 1954.....1978...

2 – 500/115kV Transformers (Three Phase)

    Adequate spacing between transformers

1 – 500kV Reactor Bank (Single Phase)

2 – 230/115kV Transformers (Three Phase)

    Adequate spacing between transformers

## Westwing 500kV Substation

### 500kV Substation Ownership

#### Navajo/Moenkopi:

APS	24.7%
SRP	38.3%
TEP	13.3%
WAPA	23.7%

#### Palo Verde:

APS	34.6%
SRP	34.6%
PNW	12.1%
EL PASO	18.7%

#### Perkins:

SRP	100%
-----	------

### 500kV Substation Ownership

#### Westwing 230kV (T1 and T4 Banks)

APS	28.5%
SRP	44.2%
WAPA	27.3%

#### Westwing 230kV (T10 Bank)

APS	43.95%
SRP	43.95%
PNW	12.1%

#### TEP 345kV (T7 Bank):

TEP	100%
-----	------

#### In Service 1973

#### 4 Transformer Banks 500/230kV, 500/345kV (Single Phase)

Fire walls to be added with transformer replacements in 2005 and 2006

#### 3 – 500kV Reactor Banks (Single Phase and Three Phase)

Adequate spacing between reactor banks

## Westwing 230kV Substation

### 230kV Switchyard Ownership

#### Common:

APS	32.1%
SRP	36.1%
WAPA	31.8%

#### T-10:

APS	43.95%
SRP	43.95%
PNW	12.1%

#### Waddell:

WAPA	100%
------	------

### 230kV Substation Ownership

APS	100%
-----	------

In Service 1986

2 Transformers 230/69kV (Three Phase)

1 – 230kV Reactor Bank (Three Phase)

## Yavapai Substation

### Switchyard and Substation:

APS	100%
-----	------

In Service 1996

2 – 500/230kV Transformers (Three Phase)

Adequate spacing between transformers

1 – 230/69kV Transformer (Three Phase)

## Preacher Canyon Substation

### Switchyard and Substation:

APS	100%
-----	------

In Service 1981

2 – 345/69kV Transformers (Three Phase)

Adequate spacing between transformers

## Four Corners Substation

### 500kV Switchyard

APS	43.33%
SCE	32%
EPE	4.67%
PSNM	8.66%
SRP	6.67%
TEP	4.67%

### 500kV/345kV Transformers:

APS	15%
SCE	48%
EPE	7%
PSNM	13%
SRP	10%
TEP	7%

### 345kV Substation

APS	40.23%
SCE	12%
EPE	10.5%
PSNM	22.62%
SRP	10%
TEP	4.85%

### 345kV Substation

APS	40.23%
SCE	12%
EPE	10.5%
PSNM	22.62%
SRP	10%
TEP	4.85%

### Connection to 345kV Substation

APS	19.25%
SCE	43.2%
EPE	6.3%
PSNM	12.95%
SRP	12%
TEP	6.3%

### 230kV Switchyard

APS	Varies %
SCE	Varies %
EPE	Varies %
PSNM	Varies %
SRP	Varies %
TEP	Varies %

- In Service 1962
- 1 – 500/345kV Transformer Bank (Single Phase)
  - Fire walls to be added in 2004/2005
- 2 – 345/230kV Transformer (Three Phase)
  - Adequate spacing between transformers
- 1 – 230/69kV Transformers (Three Phase)
- 1 – 500kV Reactor (Single Phase)
- 2 – 345kV Reactor (Single Phase and Three Phase)
  - Adequate spacing between reactor banks

## **Cholla Substation**

Switchyard and Substation:  
APS                    100%

- In Service 1961
- 2 – 500/345kV Transformer Banks (Single Phase)
- 1 – 500kV Reactor Bank (Single Phase)
- 1 – 345/230kV Transformer (Three Phase)
- 1 – 345/69kV Transformer (Three Phase)
- 1 – 230kV Reactor (Three Phase)
- 1 – 230kV Transformer (Three Phase)

## **Pinnacle Peak Substation**

Switchyard and Substation:  
APS                    100%

- In Service 1962
- 3 – 345/230kV Transformers (Three Phase)
  - Adequate spacing between transformers
- 2 – 230/69kV Transformers (Three Phase)
  - Adequate spacing between transformers