

APS Comments
VEE November 28, 2000

VEE Issue #20 – Requirements for MRSP to post final data when a customer is returning to Bundled Service

- APS will send the MDCR (Meter Data Communication Request form) at least five business days prior to the scheduled exchange date. On the scheduled date of the exchange, the MRSP will call the meter hourly to retrieve data until communication with the meter is lost.
- After the exchange is completed and the customer has returned to bundled service, APS will send the MRSP the MIRN form within three business days indicating the exact time of the exchange.
- The MRSP will be required to post data through the last full fifteen-minute interval prior to the new UDC installation. The MRSP is responsible for estimating all missing intervals to meet this requirement. If needed, the hard dial read is present on the MIRN form and may be used to assist in estimating the final intervals. All final data must go through VEE for the final validation and if 10% or more of the intervals are estimated the file must be marked as estimated.
- The final data is expected to be posted within three business days of the receipt of the MIRN form. Any exceptions should be handled through the MADEN process (yet to be developed).