ODORANT TEST RECORD

To verify odorant levels on small gas systems when an instrument is not available conduct the "Sniff Test". The use of two persons is recommended. Select one or more locations but it's preferable to use a remote location from the gas supply inlet. Vent a small amount of gas and determine if the odorant can be detected with your nose. If you cannot detect the odorant have the second person try. If odorant is detected, its concentration is adequate. If odorant cannot be detected, contact the gas supplier and the ACC to inform of potential issue. Record the results of all tests and corrective action made. It is recommended that this test be conducted quarterly.

Date	Test Location	Odorant Detected Y/N	This Test made by