

THE FOLLOWING CHARGES HAVE BEEN TENTATIVELY APPROVED
 BY THE CORPORATION COMMISSION AND SHOULD GO INTO EFFECT
 BY OCTOBER BILLING PERIOD

ORIGINAL

MONTHLY CHARGES

3	5/8" x 3/4" Meter	\$22.25
4	3/4" Meter	33.38
	1" Meter	55.63
5	1 1/2" Meter	111.25
	2" Meter	178.00
6	3" Meter	356.00
	4" Meter	556.25
7	6" Meter	1,112.50

Gallonage Charge - per 1,000 Gallons

9	1 to 3,000 gallons	\$3.50
	3,001 to 12,000	5.25
10	12,001 and up gallons	6.30

SERVICE LINE AND METER INSTALLATION CHARGES

(Refundable pursuant to A.A.C. R14-2-405)

12	5/8" x 3/4" Meter	\$420.00
13	3/4" Meter	450.00
	1" Meter	495.00
14	1 1/2" Meter	820.00
	2" Meter	1,445.00
15	3" Meter	2,085.00
16	4" Meter	3,200.00
	6" Meter	5,875.00

SERVICE CHARGES:

18	Establishment	\$30.00
19	Establishment (After Hours)	40.00
20	Reestablishment (Within 12 Months)	**
	Reconnection (Delinquent)	40.00
21	Reconnection (After Hours)	40.00
	Meter Test (If Correct)	10.00
22	Meter Reread (If Correct)	5.00
23	Deposit	*
	Deposit Interest	*
24	NSF Check	15.00
	Deferred Payment (per month)	*

* Per Commission rule A.A.C. R14-2-403(B).
 ** Months off system times the monthly minimum per Commission rule A.A.C. R14-2-403(D).

APPROVED FOR FILING
 DECISION NO. 106388

CROSS-CONNECTION OR BACKFLOW TARIFF

PURPOSE:

The purpose of this tariff is to protect Beaver Valley Water Company Inc. ("Company") from the possibility of contamination caused by the backflow of contaminants that may be present on the customer's premises by requiring the installation and periodic testing of backflow- prevention assemblies pursuant to the provisions of the Arizona Administrative Code ("A.A.C.") R14-2-405.B.6 and A.A.C. R18-4-215.

REQUIREMENTS:

In compliance with the Rules of the Arizona Corporation Commission ("Commission") and the Arizona Department of Environmental Quality ("ADEQ"), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-215 relating to backflow prevention:

1. The Company may require a customer to pay for and to have installed a backflow-prevention assembly if A.A.C. R18-4-215.B or C applies.
2. A backflow-prevention assembly required to be installed by the customer under Paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-215.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410, and in accordance with Paragraphs 1 and 7 of this tariff, the Company may terminate service or may deny service to a customer who fails to install a backflow-prevention assembly as required by this tariff
4. The Company shall give any existing customer who is required to install a backflow-prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B.1.a. is **not** applicable, the customer shall be given thirty (30) days from the time such written notice is received in which to comply with this notice. If the customer can show good cause as to why he cannot install the backflow-prevention assembly within thirty (30) days, the Company or Commission Staff may suspend this requirement for a reasonable period of time.

****FOR OFFICIAL USE ONLY****

Effective Date: October 6, 2017

**ADMINISTRATIVELY
APPROVED FOR FILING**

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-215.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location
 - c. date(s) of test(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
7. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
8. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: October 6, 2017

**ADMINISTRATIVELY
APPROVED FOR FILING**

TARIFF SCHEDULE

ORIGINAL

Miller

Utility: BEAVER VALLEY WATER
Docket No.: 2015
Phone No.: 928-474-5759

Tariff Sheet No.: 1 of 3
Decision No.: RECEIVED
Effective: JULY 20, 2002

2002 JUN 20 A 1:06

CURTAILMENT PLAN FOR:

ADEQ Public Water System Number: 04-004

W-02015A-02-0458

BEAVER VALLEY WATER ("Company") is authorized to curtail water service to all customers, residential and commercial, within its certificated area under the following terms and conditions:

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as steadily declining water table, an increased draw-down threatening pump operations, or poor water production creating a reasonable belief the Company will be unable to meet anticipated water demands in the system.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

I:\JAC\mydocs\CurtailmentPlanTariff.doc

ARIZONA CORPORATION COMMISSION

RECEIVED
JUN 20 2002

REVISED: MAY 31, 2002

Director of Utilities

ADMINISTRATIVELY APPROVED FOR FILING

Rtd
6-20

TARIFF SCHEDULE

ORIGINAL

Utility: BEAVER VALLEY WATER CO.
Docket No.: 2015
Phone No.: 528-474-5759

Tariff Sheet No.: 2 of 3
Decision No.: _____
Effective: July 20, 2002

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customer to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible.

Notice Requirements:

- 1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
- 2. Beginning with Stage 3, Company shall post at least two (2) signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to the major subdivision served by the Company.
- 3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect in an attempt to maintain the level at a level no greater than stage three until a permanent solution has been implemented.

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

TARIFF SCHEDULE

ORIGINAL

Utility: BEAVER VALLEY WATER Co.
Docket No.: 2015
Phone No.: 928-474-5759

Tariff Sheet No.: 3 of 3
Decision No.: _____
Effective: July 20, 2002

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- Washing of any vehicle is prohibited
- The use of water for dust control or any outdoor cleaning uses is prohibited
- The use of drip or misting systems of any kind is prohibited
- The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- Restaurant patrons shall be served water only upon request
- Any other water intensive activity is prohibited

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least two (2) signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to the major subdivision served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering stage 4.

Customers who fail to comply with cessation of outdoor use provisions will be given a written notice to end all outdoor use. Failure to comply with in two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees.

Once Stage 4 has been reached, the Company must begin to augment the supply of water by continuing to hauling or through an emergency interconnect in an attempt to maintain the level at a level no greater than stage 4 until a permanent solution has been implemented.

Note: If the Company loses all well production and has no storage facilities, the Company must provide water by hauling to at least meet the minimum needs to the customers or must otherwise provide emergency drinking water for its customers.

ADMINISTRATIVELY
APPROVED FOR FILING