

pat
WILLIAM A. MUNDELL
CHAIRMAN
JIM IRVIN
COMMISSIONER
MARC SPITZER
COMMISSIONER



ORIGINAL

BRIAN C. McNEIL
EXECUTIVE SECRETARY

RECEIVED

ARIZONA CORPORATION COMMISSION
UTILITIES DIVISION
1200 W. WASHINGTON STREET
PHOENIX, AZ 85007

2002 OCT -4 P 1:15

AZ CORP COMMISSION
DOCUMENT CONTROL

13 5 to the Engineering Report attached to the ...

14 ORDER

15 IT IS THEREFORE ORDERED that Roosevelt Lake Resort, Inc. is hereby directed to file on
16 or before September 30, 2002, revised rate schedules setting forth the following rates and charges:

17 MONTHLY USAGE CHARGE:

18

| | |
|---------------------------------------|----------|
| 19 5/8" x 3/4" Meter | \$ 17.00 |
| 3/4" Meter | 20.00 |
| 20 1" Meter | 30.00 |
| 1 1/2" Meter | 60.00 |
| 21 2" Meter | 93.00 |
| 3" Meter | 170.00 |
| 22 4" Meter | 300.00 |
| 23 6" Meter | 600.00 |
| 24 Gallonage charge per 1,000 gallons | 3.88 |

25 SERVICE LINE AND METER INSTALLATION CHARGES:

26 (Refundable pursuant to A.A.C. R14-2-40-5)


27

| | |
|-------------------|-----------|
| 5/8" x 3/4" Meter | \$ 450.00 |
| 3/4" Meter | 500.00 |
| 28 1" Meter | 600.00 |

8

DECISION NO. 65218

ARIZONA CORPORATION
COMMISSION



Director of Utilities

APPROVED FOR FILING

DECISION #: 65218

ORIGINAL

| | | |
|---|--------------|-----------|
| 1 | 1 1/2" Meter | \$ 800.00 |
| 2 | 2" Meter | 1,400.00 |
| 3 | 3" Meter | 2,000.00 |
| 4 | 4" Meter | 3,100.00 |
| 5 | 6" Meter | 5,700.00 |

4 SERVICE CHARGE:

| | | |
|----|------------------------------------|---------|
| 5 | Establishment | \$20.00 |
| 6 | Establishment (After Hours) | 35.00 |
| 7 | Reconnection (Delinquent) | 35.00 |
| 8 | Meter Test (If Correct) | 15.00 |
| 9 | Deposit | * |
| 10 | Deposit Interest | * |
| 11 | Reestablishment (Within 12 Months) | ** |
| 12 | NSF Check | 20.00 |
| 13 | Deferred Payment (per month) | 1.50% |
| 14 | Meter Reread (If Correct) | 10.00 |
| 15 | Late Payment Penalty (per month) | 1.5% |
| 16 | Meter Move (Customer Request) | Cost |
| 17 | Road Cuts and Repaving | Cost |

13 Monthly Service Charge for Fire Sprinklers:

| | | |
|----|-----------------|-----|
| 14 | 4" or Smaller | *** |
| 15 | 6" | *** |
| 16 | 8" | *** |
| 17 | 10" | *** |
| 18 | Larger than 10" | *** |

- 17 * Per Commission rule A.A.C. R-14-2-403(B).
- 18 ** Number of months off system times the monthly minimum per Commission rule A.A.C. R14-2-403(D).
- 19 *** 1.00% of Monthly Minimum for a Comparable Sized Meter Connection, but no less than \$5.00 per month. The Service Charge for Fire Sprinklers is only applicable for service lines separate and distinct from the primary water service line.

21 IT IS FURTHER ORDERED that the above water rates and charges shall be effective for all
 22 services provided on and after October 1, 2002.

23 IT IS FURTHER ORDERED that Roosevelt Lake Resort, Inc. shall notify its customers of
 24 the rates and charges authorized hereinabove and the effective date of same by means of an insert in
 25 its next regular monthly billing, and file, within 60 days of the effective date of this Decision, a copy
 26 of the notice with the Compliance Section of the Commission's Utilities Division.

27 ...

28

APPROVED FOR FILING
 DECISION #: 65218
 DECISION NO. _____



ORIGINAL

50

Utility: ROOSEVELT LAKE
Docket No. W-01958A-02-0283
Phone No.: (480)945-8718

1 of 4
Decision No.: 652 RECEIVED
Effective: 9/24/02

2003 JAN 10 P 3:17

CURTAILMENT PLAN FOR ROOSEVELT LAKE RESORT, INC.
AZ CORP COMMISSION
DOCUMENT CONTROL

ADEQ Public Water System #04-018

Roosevelt Lake Resort, Inc. ("Company") is authorized to curtail water service to all customers within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan for the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Arizona Corporation Commission

DOCKETED

JAN 10 2003

Stage 2 Exists When:

DOCKETED BY CAR

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

Ja Frank
OWNER/OPERATOR

TARIFF SCHEDULE

Utility: ROOSEVELT LAKE RESORT, INC.
Docket No.: W-0195A-02-0293
Phone No.: (880) 945-8718

Tariff Sheet No.: 3 of 4
Decision No.: 65218
Effective: SEPT 24, 2002

- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least two signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering stage 4.

Customers who fail to comply with the above Restrictions will be given a written notice to end all outdoor use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees.

If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation. Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through

Ja Leach Jr.
OWNER/OPERATOR

ORIGINAL

Effective Date: _____

Company Name: ROOSEVELT LAKE RESORT, INC. (w-1958)

Page 2 of 2

5. Testing shall be in conformance with the requirements of A.A.C. R18-4-115.F. The Company may require the customer to pay to have the backflow-prevention assembly tested as long as the Company does not require an unreasonable number of tests.
6. The customer shall provide the Company with records of installation and testing. For each backflow-prevention assembly, these records shall include:
 - a. assembly identification number and description;
 - b. location;
 - c. date(s) of tests(s);
 - d. description of repairs and recommendations for repairs made by tester; and
 - e. the tester's name and certificate number.
- 7A. In the event the backflow-prevention assembly does not function properly or fails any test, and an obvious hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, the Company may terminate service immediately and without notice. The backflow-prevention assembly shall be repaired or replaced by the customer and retested.
- 8A. In the event the backflow-prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement, and A.A.C. R14-2-410.B.1.a. is **not** applicable, the backflow-prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or dysfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

****FOR OFFICIAL USE ONLY****

Effective Date: April 11, 2002

**ADMINISTRATIVELY
APPROVED FOR FILING**