

ORIGINAL

WATER TARIFF SCHEDULE

UTILITY: Sedona Venture - Water Division
 DOCKET NO.: W-02414A-99-0407

DECISION NO.: _____
 EFFECTIVE: April 1, 2000

RATES AND CHARGES

CUSTOMER/MINIMUM CHARGES PER MONTH		SERVICE LINE & METER INSTALLATION CHARGES	
<u>METER</u>	<u>CHARGES</u>	<u>METERS</u>	<u>CHARGES</u>
5/8"	\$ 9.65	5/8"	\$ 347.00
3/4"	\$ 15.00	3/4"	\$ 385.00
1"	\$ 44.00	1"	\$ 450.00
1 1/2"	\$ 60.00	1 1/2"	\$ 665.00
2"	\$ 80.00	2"	\$ 1,050.00
3"	\$ 160.00	3"	\$ 1,430.00
4"	\$ 250.00	4"	\$ 2,295.00
6"	\$ 500.00	6"	\$ 4,400.00

Commodity Rate - per 1,000 Gallons

From 1 to 10,000 Gallons	\$ 1.50
In excess of 10,000 Gallons	\$ 2.40

SERVICE CHARGES:

1. ESTABLISHMENT	\$20.00
2. ESTABLISHMENT (AFTER HOURS)	\$40.00
3. RECONNECTION (DELINQUENT)	\$30.00
4. METER TEST (IF CORRECT)	\$30.00
5. DEPOSIT	*
6. DEPOSIT INTEREST	*
7. RE-ESTABLISHMENT (W/IN 12 MONTHS)	**
8. NSF CHECK	\$15.00
9. DEFERRED PAYMENT (PER MONTH)	1.50%
10. METER REREAD (IF CORRECT)	\$15.00

Monthly Service Charge for Fire Sprinkler

4" or Smaller	***
6"	***
8"	***
10"	***
Larger than 10"	***

- * Per Commission Rule R14-2-403.B.7 and 403.B.3.
- ** Months off system times the minimum (R14-2-403.D)

APPROVED FOR FILING

DECISION #: 62405

ORIGINAL

*** 1.00% of monthly minimum for a comparable sized meter connection, but no less than \$5.00 per month. The service charge for fire sprinklers is only applicable for service lines separate and distinct from the primary water service line.

OTHER RATES AND CHARGES APPROVED BY ORDER:

IN ADDITION TO THE COLLECTION OF ITS REGULAR RATES AND CHARGES, SEDONA VENTURE - WATER DIVISION SHALL COLLECT FROM ITS CUSTOMERS A PROPORTIONATE SHARE OF ANY PRIVILEGE, SALES OR USE TAX IN ACCORDANCE WITH R14-2-409.D.5.

APPROVED FOR FILING
DECISION #: 62425

TARIFF SCHEDULE

Utility: dba Sedona Venture Water Co.
Docket No.: WS-03449A-04-0569
Phone No.: 928-282-1136

ORIGINAL

Sheet No: 1 of 4
Decision No.: _____
Effective: 8-24-04

CURTAILMENT PLAN FOR SEDONA VENTURE WATER CO.
(Template 063004)

ADEQ Public Water System No: 13-108

Sedona Venture Water Co. ("Company") is authorized to curtail water service to all customers within its certificated area under the terms and conditions listed in this tariff.

This curtailment plan shall become part of the Arizona Department of Environmental Quality Emergency Operations Plan for the Company.

The Company shall notify its customers of this new tariff as part of its next regularly scheduled billing after the effective date of the tariff or no later than sixty (60) days after the effective date of the tariff.

The Company shall provide a copy of the curtailment tariff to any customer, upon request.

Stage 1 Exists When:

Company is able to maintain water storage in the system at 100 percent of capacity and there are no known problems with its well production or water storage in the system.

Restrictions: Under Stage 1, Company is deemed to be operating normally and no curtailment is necessary.

Notice Requirements: Under Stage 1, no notice is necessary.

Stage 2 Exists When:

- a. Company's water storage or well production has been less than 80 percent of capacity for at least 48 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 2, the Company may request the customers to voluntarily employ water conservation measures to reduce water consumption by approximately 50 percent. Outside watering should be limited to essential water, dividing outside watering on some uniform basis (such as even and odd days) and eliminating outside watering on weekends and holidays.

ADMINISTRATIVELY
APPROVED FOR FILING

TARIFF SCHEDULE

Utility: dba Sedona Venture Water Co.
Docket No.: WS-03449A-04-0569
Phone No.: 928-282-1136

ORIGINAL

Sheet No: 2 of 4
Decision No.: _____
Effective: 8-24-04

Notice Requirements: Under Stage 2, the Company is required to notify customers by delivering written notice door to door at each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.

Stage 3 Exists When:

- a. Company's total water storage or well production has been less than 50 percent of capacity for at least 24 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 3, Company shall request the customers to voluntarily employ water conservation measures to reduce daily consumption by approximately 50 percent. All outside watering should be eliminated, except livestock, and indoor water conservation techniques should be employed whenever possible. Standpipe service shall be suspended.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such Notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Beginning with Stage 3, Company shall post at least 4 signs showing the curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 3.

Once Stage 3 has been reached, the Company must begin to augment the supply of water by either hauling or through an emergency interconnect with an approved water supply in an attempt to maintain the curtailment at a level no higher than Stage 3 until a permanent solution has been implemented.

ADMINISTRATIVELY
APPROVED FOR FILING

TARIFF SCHEDULE

Utility: dba Sedona Venture Water Co.
Docket No.: WS-03449A-04-0569
Phone No.: 928-282-1136

Sheet No: 3 of 4
Decision No.: _____
Effective: 8-24-04

ORIGINAL

Stage 4 Exists When:

- a. Company's total water storage or well production has been less than 25 percent of capacity for at least 12 consecutive hours, and
- b. Company has identified issues such as a steadily declining water table, increased draw down threatening pump operations, or poor water production, creating a reasonable belief the Company will be unable to meet anticipated water demand on a sustained basis.

Restrictions: Under Stage 4, Company shall inform the customers of a **mandatory** restriction to employ water conservation measures to reduce daily consumption. Failure to comply will result in customer disconnection. The following uses of water shall be prohibited:

- ◆ Irrigation of outdoor lawns, trees, shrubs, or any plant life is prohibited
- ◆ Washing of any vehicle is prohibited
- ◆ The use of water for dust control or any outdoor cleaning uses is prohibited
- ◆ The use of drip or misting systems of any kind is prohibited
- ◆ The filling of any swimming pool, spas, fountains or ornamental pools is prohibited
- ◆ The use of construction water is prohibited
- ◆ Restaurant patrons shall be served water only upon request
- ◆ Any other water intensive activity is prohibited

The Company's operation of its standpipe service is prohibited. The addition of new service lines and meter installations is prohibited.

Notice Requirements:

1. Company is required to notify customers by delivering written notice to each service address, or by United States first class mail to the billing address or, at the Company's option, both. Such notice shall notify the customers of the general nature of the problem and the need to conserve water.
2. Company shall post at least 4 signs showing curtailment stage. Signs shall be posted at noticeable locations, like at the well sites and at the entrance to major subdivisions served by the Company.
3. Company shall notify the Consumer Services Section of the Utilities Division of the Corporation Commission at least 12 hours prior to entering Stage 4.

ADMINISTRATIVELY
APPROVED FOR FILING

TARIFF SCHEDULE

Utility: dba Sedona Venture Water Co.
Docket No.: WS-03449A-04-0569
Phone No.: 928-282-1136

ORIGINAL

Sheet No: 4 of 4
Decision No.: _____
Effective: 8-24-04

Once Stage 4 has been reached, the Company must augment the supply of water by hauling or through an emergency interconnect from an approved supply or must otherwise provide emergency drinking water for its customers until a permanent solution has been implemented.

Customers who fail to comply with the above restrictions will be given a written notice to end all outdoor use. Failure to comply within two (2) working days of receipt of the notice will result in temporary loss of service until an agreement can be made to end unauthorized use of outdoor water. To restore service, the customer shall be required to pay all authorized reconnection fees. If a customer believes he/she has been disconnected in error, the customer may contact the Commission's Consumer Services Section at 1-800-222-7000 to initiate an investigation.

ADMINISTRATIVELY
APPROVED FOR FILING

ORIGINAL

THE SEDONA VENTURE
6770 West US 89A
Sedona, Arizona 86336
(602) 282-1232

CROSS-CONNECTION OR BACKFLOW TARIFF

APPLICABILITY:

All customers served by The Sedona Venture Water Company (hereinafter called "The Water Company").

PURPOSE:

To protect the public water supply from the possibility of contamination caused by backflow through unprotected cross-connections by requiring installation and periodic testing of backflow prevention assemblies pursuant to provisions of Arizona Administrative Code (A.A.C.) R14-2-405.B.6 and A.A.C. R18-4-232.

REQUIREMENTS:

In compliance with the rules and regulations of the Arizona Corporation Commission and the Arizona Department of Environmental Quality (ADEQ), specifically A.A.C. R14-2-405.B.6 and A.A.C. R18-4-232 relating to backflow prevention:

1. The Water Company may require a customer to pay for and install a backflow prevention assembly if A.A.C. R18-4-232.B or C applies.
2. A backflow prevention assembly required to be installed by the customer under paragraph 1 of this tariff shall comply with the requirements set forth in A.A.C. R18-4-232.D and E.
3. Subject to the provisions of A.A.C. R14-2-407 and 410 and in accordance with paragraphs 1 and 7 of this tariff, The Water Company may terminate service or deny service to a customer who fails to install a backflow prevention assembly as required by this tariff.
4. The Water Company shall give any existing customer who is required to install a backflow prevention assembly written notice of said requirement. If A.A.C. R14-2-410.B1.a. is not applicable, the customer shall be given thirty (30) days in which to comply with this notice. If the customer can show good cause as to why he cannot install the device within thirty (30) days, The Water Company or Commission Staff may suspend this requirement for a reasonable period of time.
5. Testing shall be in conformance with the requirements of A.A.C. R18-4-232F. The Water

APPROVED FOR FILING

DECISION #: 58555

EFFECTIVE: 3/16/94

Company may require the customer to pay to have the backflow prevention assembly tested as long as the Company does not require an unreasonable number of tests. The Water Company may also require the customer to pay for repairs to a backflow prevention assembly.

6. The customer shall provide The Water Company with records of installation and testing. For each backflow prevention assembly, these records shall include:
 - a. Assembly identification number and description;
 - b. Location;
 - c. Date(s) of test(s);
 - d. Description of repairs and recommendations for repairs made by tester; and
 - e. The tester's name and certificate number.

7(A) In the event the backflow prevention assembly does not function properly or fails any test, and a hazard as contemplated under A.A.C. R14-2-410.B.1.a. exists, The Water Company may terminate service immediately and without notice. The backflow prevention assembly shall be repaired or replaced by the customer and retested before service is restored.

7(B) In the event the backflow prevention assembly does not function properly or fails any test, or in the event that a customer fails to comply with the testing requirement and A.A.C. R14-2-410.B.1.a. is not applicable, the backflow prevention assembly shall be repaired or replaced within fourteen (14) days of the initial discovery of the deficiency in the assembly or its function. Failure to remedy the deficiency or disfunction of the assembly, or failure to retest, shall be grounds for termination of water service in accordance with A.A.C. R14-2-410.

APPROVED FOR FILING

DECISION #: 58555

Effective: 3/16/94